HARVARD CAMPUS SERVICES

HOLYOKE EIGHTH FLOOR | CAMPUS SERVICE CENTER

75 Mount Auburn Street, Cambridge, MA 02138

LEED-CI v3 Gold

The Harvard Campus Service Center LEED-CI project is an interior renovation of existing office space located within the Harvard University Housing office suite on the eighth floor of the Holyoke Center to accommodate the expanded needs of the Harvard University Campus Services and Transportation Services Department. The purpose of the new Campus Services Center is to provide a single location conveniently located within Harvard Square for Harvard students, faculty and staff to visit when seeking University housing, parking permits, and identification cards. Existing office spaces were removed to create the open floor space required for the new programming, which includes eight flexible customer transaction stations to meet peak customer demands.

The new space was sustainably renovated at a minimal expense and the project team strived to meet their sustainability goals which included maintaining and reusing a significant portion of the non-structural interior,



Campus Service Center Photo: Harvard Green Building Services, 2011.

salvaging and reusing materials, furniture and furnishings and the use of recycled and regional materials. In consideration of the surrounding tenants and to insure healthy indoor environmental quality, an IAQ management plan was implemented and the construction site was isolated from the building's HVAC system.

The new Campus Service Center's open floor plan allows the project to take advantage of the window-wrapped perimeter, to provide natural daylight to 75% of the space and direct views for more than 80% of the regularly occupied spaces. As a central hub of University activity, the space will feature signage to educate future occupants and visitors about the many sustainable features included in the LEED renovation, including the flexible and multipurpose layout and design.

PROJECT HIGHLIGHTS

LEED® Facts Holyoke Campus Service Center Harvard Campus Services 2011
LocationCambridge, MA Rating SystemLEED-CI v.3

LocationCambridge, MA
Rating SystemLEED-Cl v.3
CertificationGold
Total Points70/110
Sustainable Sites
Water Efficiency 11/11
Energy and Atmosphere15/37
Materials and Resources8/14
Indoor Environmental Quality 7/17
Innovation in Design 6/6
Regional Priority3/4

of the regularly occupied spaces are **75%** daylit.

40% reduction in water consumption.

of the total material value consists of 43% products manufactured and/or extracted locally.


of the total materials value was 68% comprised of salvaged, refurbished, or reused furnishings.

of the project's construction and 90% demolition debris was diverted from the landfill.



PROJECT OVERVIEW

CAMPUS SERVICES FLOOR PLAN & LEED BOUNDARY



Harvard Campus Services LEED Boundary

Photo: Galante Architecture Studio, 2011.



Campus	Services	Entrance	
Photo: Gree	n Building Se	ervices, 2011	

PROJECT T	ГЕАМ			
Owner	Harvard Campus Services			
Project Manager	Jones Lang LaSalle			
Architect	Galante Architecture Studio			
Contractor	Shawmut Design and Construction			
MEP Engineer	BLW Engineers, Inc.			
Commissioning Authority	Facility Dynamics			
Sustainability Consultant	Harvard Green Building Services			



GREEN is the new Crimson

SITE



Harvard Holyoke Center Cambridge, MA



- ➤ To encourage alternatives to driving, all occupants of Campus Service Center and the Holyoke Center base building have access to Harvard's comprehensive *CommuterChoice Program*, which provides incentives and discounts for all modes of alternative transportation as well as carpooling and fuel efficient vehicles.
- ➤ The building is located within walking distance to the Harvard Square MBTA stop, several bus lines, and the Harvard University Shuttle.
- ➤ Bicycle racks are available for use by the building's occupants located both in the building's basement and directly adjacent to both the east and west sides of the building.
- ➤ The building is located in a dense urban area, which allows occupants to walk and easily access amenities such as restaurants, banks, churches, and retail stores.
- Holyoke Center
- MBTA Bus Stops
- MBTA Subway Station



Bike Racks at Holyoke Center Photo: Green Building Services, 2010.

WATER EFFICIENCY

Per LEED requirements, if a project boundary does not include restrooms, calculations must be for the fixtures in the closest restroom. The closest bathrooms to the Campus Service Center have water efficient fixtures, which reduce domestic water consumption by 40% over standard EPAct 1992 fixtures.

Differences in the Flush & Flow Rates for EPAct 1992 Standard Fixtures and the fixtures installed for the project

· · · · · · · · · · · · · · · · · · ·							
Fixture Type	Flush & Flow Rates	EPAct 1992 Standard Flush & Flow Rates					
Water Closet [GPF]	1.35	1.6					
Urinal [GPF]	0	1.0					
Sink [Gallons per cycle]	0.13	2.5					
Shower [GPM]	1.6	2.5					
GPF - Gallons Per Flush	GPM - Gallons Per Minut	e					

FIXTURES IN HOLYOKE CENTER





Sloan Uppercut® Dual-flush Water Closet 1.1—1.6 gpf







ENERGY EFFICIENCY

Harvard Campus Services has committed, along with Harvard University as a whole, to reduce greenhouse gas emissions 30% below 2006 levels by 2016, inclusive of growth.

MECHANICAL SYSTEMS

The HVAC SYSTEM is separately zoned and controlled to account for equipment loads and solar heat gain. There are multiple separate zones within the Campus Service Center, which allows for controllability of thermal systems and helps to maintain the thermal comfort of occupants.

Advanced **SIEMENS CONTROL SYSTEMS** allow for the interoperability of occupancy sensors with lighting and HVAC systems. Moreover, where occupancy does not drive HVAC setbacks, time-clock settings adjust airflow and temperature set-points.

COMMISSIONING: The mechanical and electrical systems within the Campus Service Center were fully commissioned, which helps ensure that all energy-related systems were installed in accordance with the manufacturer's specifications and operating efficiently prior to occupancy.

ELECTRICAL SYSTEMS

HIGH EFFICIENCY LIGHTING: Existing lighting fixtures were retrofitted with energy-efficient fluorescent lamps to reduce electricity consumption. These and other lighting reductions reduced the lighting power density (watts per square feet) by 27.5% below code.

To reduce the amount of toxic material in the building, linear fluorescent lighting which was chosen instead of compact fluorescent lighting wherever possible contains less mercury.

OCCUPANCY SENSORS were strategically placed throughout the project to sense the presence of people. Occupancy sensors have the ability to turn off all room lighting upon room vacancy.

DAYLIGHTING: 75% Of the regularly occupied space in the Campus Services Center receives natural daylight from the perimeter windows, affording the option to reduce the electrical lighting load.



Harvard Campus ServicesPhotos: Green Building Services, 2011.



Harvard Campus ServicesPhotos: Green Building Services, 2011.



INDOOR ENVIRONMENTAL QUALITY

Harvard Campus Services is committed to providing a healthy indoor environment for all occupants. The project team was careful to maintain healthy indoor air quality during construction and to also ensure the space is designed to promote healthy indoor air quality during occupancy.

INDOOR AIR QUALITY DURING CONSTRUCTION: During the renovation, the construction team implemented an Indoor Air Quality Management plan to ensure the health of the workers and the eventual inhabitants. Some of the aspects of the plan included walk-off mats to reduce the amount of debris tracked into the project, masking all return grills and ventilation with polyethylene sheets, green sweep practices, and storing all materials in cool, dry areas to prevent mold.

THERMAL COMFORT SURVEY: Occupants will be surveyed about their thermal comfort once per season. The Operations team will adjust the heating or cooling in the project space as needed.

Only materials with LOW OR NO VOC CONTENT were used in the Campus Services project. Volatile Organic Compounds (VOCs) are chemical compounds and known carcinogens found in many construction materials that are considered detrimental to indoor air quality. Reducing the use of VOCs whenever possible improves indoor air quality and consequently occupant health and productivity.

- ➤ COMPOSITE WOOD AND LAMINATE ADHESIVES used do not have any added urea formaldehyde.
- ➤ CARPET SYSTEMS that were installed are CIR Green Label Plus certified products.
- ➤ ADHESIVES AND SEALANTS | PAINTS AND COATINGS Example products:

Product Category	Product & Manufacturer	VOC Content (g/l)	VOC Limit (g/l)	Standard
	> Sherwin William—Pro Green Primer	44	150	GS-11
Paints & Coatings	➤ Sherwin William—Pro Green Eggshell	40	150	GS-11
	➤ Sherwin William—Pro Green Semi-Gloss	46	150	GS-11
Adhesives &	> Mapei—Ultrabond ECO	0	50	SCAQMD #1168
Sealants	> Wilsonart Contact Adhesive	3	80	SCAQMD #1168



Housekeeping Sticky Walk-off Mats



Source Control Sealing work areas





VIEWS: To provide a connection between indoor and outdoor environments, **84%** of the occupied spaces have access to views.

GREEN HOUSEKEEPING: Harvard has made a commitment to using green cleaning processes in its buildings, including the Holyoke Center. This includes the use of Green Seal certified cleaning solutions, 100% recycled content toilet tissue and paper towels, portion control chemical dispensers, and staff training.







MATERIALS & WASTE

Selecting environmentally preferable materials and minimizing the amount of construction waste sent to landfill was important to the project. The project gave preference to low-emitting materials with recycled content and locally manufactured.

- 46% of the total material value consists of products salvaged or manufactured locally.
- 90% of the on-site generated construction waste was diverted from the landfill.
- 17% of the total value of materials used in the project consist of materials with recycled content.



Campus Service Center Photos: Green Building Services, 2011.

ENVIRONMENTALLY PREFERABLE MATERIALS

- Hardware (Rakks)
 41% pre-consumer, 23% post-consumer recycled content
- Metal Framing (Dietrich Steel)
 36% pre-consumer, 17% post-consumer recycled content
- Insulation (Owens Corning)
 50% pre-consumer, 10% post-consumer recycled content
- ACT Panels (Armstrong)
 67% pre-consumer, 4% post-consumer recycled content

Examples of regional materials used in project:

Material Name	Manufacturer	Distance between Project & Manufacturer (mi)		
Anti-Rust Coating	Sherwin Williams	348		
Metal Framing	Dietrich Steel	198		
Paint (semi-Gloss)	Sherwin Williams	348		



ADDITIONAL RESOURCES

- > HARVARD CAMPUS SERVICES: http://www.campusservices.harvard.edu
- ➤ HARVARD CAMPUS SERVICES CENTER: http://www.campusservicecenter.harvard.edu/
- > HARVARD GREEN BUILDING SERVICES: http://green.harvard.edu/green-building-services
- > HARVARD GREEN BUILDING RESOURCE: http://green.harvard.edu/theresource



						Harvard Campus Service Center - LEED-Cl v LEED GOLD: 04/25/2012	3 Scorecard
20	0	0	0	21 Points		SUSTAINABLE SITES	
				5	SSc1	Site Selection Select a LEED certified building	
				up to 5	0001	OR a Building with following characteristics:	
			<u> </u>	1	Option 1A	Brownfield Redevelopment	
				1	Option 1B	Stormwater Design, Quantity Control	
				1	Option 1C	Stormwater Design, Quality Control	
				1	Option 1D	Heat Island Effect, Non-Roof	
1				1	Option 1E	Heat Island Effect, Roof	
				1	Option 1F	Light Pollution Reduction	
				2	Option 1G	Water Efficient Landscaping, Reduce by 50%	
				2	Option 1H	Water Efficient Landscaping, No Potable Use	
				2	Option 1I	Innovative Wastewater Technologies	
1				1	Option 1J	Water Use Reduction, 30% Reduction	
				2	Option 1K	On-Site Renewable Energy	
1				1	Option 1L	Other Quantifiable Environmental Performance: Green Cleaning	
6			<u></u>	6	SSc2	Dev. Density & Community Connectivity	
6			<u></u>	6	SSc3.1	Alt. Transportation, Public Transportation	
3			<u></u>	2	SSc3.2	Alt. Transportation, Bicycles (RP)	
2				2	SSc3.3	Alt. Transportation, Parking Availability	
11	0	0	0	11 Points		WATER EFFICIENCY	
	١	Y		Required	WEp1	WE Prereq 1 Water Use Reduction, 20% Reduction	
						WEc1 Water Use Reduction, 30%, 35%, 40%	
				6 to 11	WEc1	30% Reduction	
				01011	WECT	35% Reduction	
11						40% Reduction (RP)	
15	0	0	0	37 Points		ENERGY & ATMOSPHERE	
	•	U					
	١			Required	EA prereq 1	Fundamental Commissioning	
	``	Y		Required		Fundamental Commissioning Minimum Energy Performance	
		Y			EA prereq 1		
	``	Y Y		Required	EA prereq 2	Minimum Energy Performance 10% Reduction in lighting power density from ASHRAE 90.1-2007	
	``	Y Y		Required Required	EA prereq 2	Minimum Energy Performance 10% Reduction in lighting power density from ASHRAE 90.1-2007 AND	
	``	Y Y		Required Required	EA prereq 2	Minimum Energy Performance 10% Reduction in lighting power density from ASHRAE 90.1-2007 AND Fundamental Refrigerant Management	
2	``	Y Y		Required Required	EA prereq 2	Minimum Energy Performance 10% Reduction in lighting power density from ASHRAE 90.1-2007 AND Fundamental Refrigerant Management Optimize Energy Performance: Lighting Power	
2	``	Y Y		Required Required	EA prereq 2	Minimum Energy Performance 10% Reduction in lighting power density from ASHRAE 90.1-2007 AND Fundamental Refrigerant Management Optimize Energy Performance: Lighting Power Reduce power density to 15% below Standard	
2	``	Y Y		Required Required	EA prereq 2	Minimum Energy Performance 10% Reduction in lighting power density from ASHRAE 90.1-2007 AND Fundamental Refrigerant Management Optimize Energy Performance: Lighting Power Reduce power density to 15% below Standard Reduce power density to 20% below Standard	
2	``	Y Y		Required Required	EA prereq 2	Minimum Energy Performance 10% Reduction in lighting power density from ASHRAE 90.1-2007 AND Fundamental Refrigerant Management Optimize Energy Performance: Lighting Power Reduce power density to 15% below Standard Reduce power density to 20% below Standard Reduce power density to 25% below Standard	
2	``	Y Y		Required Required	EA prereq 2	Minimum Energy Performance 10% Reduction in lighting power density from ASHRAE 90.1-2007 AND Fundamental Refrigerant Management Optimize Energy Performance: Lighting Power Reduce power density to 15% below Standard Reduce power density to 20% below Standard Reduce power density to 25% below Standard (RP) Reduce power density to 30% below Standard	
2	``	Y Y		Required Required 1 to 5	EA prereq 2 EA prereq 3 EAc1.1	Minimum Energy Performance 10% Reduction in lighting power density from ASHRAE 90.1-2007 AND Fundamental Refrigerant Management Optimize Energy Performance: Lighting Power Reduce power density to 15% below Standard Reduce power density to 20% below Standard Reduce power density to 25% below Standard (RP) Reduce power density to 30% below Standard Reduce power density to 35% below Standard	
2	``	Y Y		Required Required	EA prereq 2	Minimum Energy Performance 10% Reduction in lighting power density from ASHRAE 90.1-2007 AND Fundamental Refrigerant Management Optimize Energy Performance: Lighting Power Reduce power density to 15% below Standard Reduce power density to 20% below Standard Reduce power density to 25% below Standard (RP) Reduce power density to 35% below Standard Reduce power density to 35% below Standard Optimize Energy Performance: Light Controls	
2	``	Y Y		Required Required 1 to 5	EA prereq 2 EA prereq 3 EAc1.1	Minimum Energy Performance 10% Reduction in lighting power density from ASHRAE 90.1-2007 AND Fundamental Refrigerant Management Optimize Energy Performance: Lighting Power Reduce power density to 15% below Standard Reduce power density to 20% below Standard Reduce power density to 25% below Standard Reduce power density to 30% below Standard Reduce power density to 30% below Standard Reduce power density to 35% below Standard Optimize Energy Performance: Light Controls Option A - Daylight responsive controls within 15' of windows	
	``	Y Y		Required Required 1 to 5	EA prereq 2 EA prereq 3 EAc1.1	Minimum Energy Performance 10% Reduction in lighting power density from ASHRAE 90.1-2007 AND Fundamental Refrigerant Management Optimize Energy Performance: Lighting Power Reduce power density to 15% below Standard Reduce power density to 20% below Standard Reduce power density to 25% below Standard Reduce power density to 25% below Standard Reduce power density to 30% below Standard Reduce power density to 35% below Standard Optimize Energy Performance: Light Controls Option A - Daylight responsive controls within 15' of windows Option B - Daylight responsive controls for 50% of load	
	``	Y Y		Required Required 1 to 5	EA prereq 2 EA prereq 3 EAc1.1	Minimum Energy Performance 10% Reduction in lighting power density from ASHRAE 90.1-2007 AND Fundamental Refrigerant Management Optimize Energy Performance: Lighting Power Reduce power density to 15% below Standard Reduce power density to 20% below Standard Reduce power density to 25% below Standard Reduce power density to 30% below Standard Reduce power density to 30% below Standard Reduce power density to 35% below Standard Optimize Energy Performance: Light Controls Option A - Daylight responsive controls within 15' of windows Option B - Daylight responsive controls for 50% of load Option C - Occupancy controls for 75% of load	
	``	Y Y		Required Required 1 to 5	EA prereq 2 EA prereq 3 EAc1.1	Minimum Energy Performance 10% Reduction in lighting power density from ASHRAE 90.1-2007 AND Fundamental Refrigerant Management Optimize Energy Performance: Lighting Power Reduce power density to 15% below Standard Reduce power density to 20% below Standard Reduce power density to 25% below Standard Reduce power density to 35% below Standard Reduce power density to 30% below Standard Reduce power density to 35% below Standard Optimize Energy Performance: Light Controls Option A - Daylight responsive controls within 15' of windows Option B - Daylight responsive controls for 50% of load Optimize Energy Performance: HVAC	
	``	Y Y		Required Required 1 to 5	EA prereq 2 EA prereq 3 EAc1.1	Minimum Energy Performance 10% Reduction in lighting power density from ASHRAE 90.1-2007 AND Fundamental Refrigerant Management Optimize Energy Performance: Lighting Power Reduce power density to 15% below Standard Reduce power density to 20% below Standard Reduce power density to 25% below Standard Reduce power density to 35% below Standard Reduce power density to 30% below Standard Reduce power density to 35% below Standard Optimize Energy Performance: Light Controls Option A - Daylight responsive controls within 15' of windows Option B - Daylight responsive controls for 50% of load Optimize Energy Performance: HVAC Option A - Equipment Efficiency and Zoning & Controls (RP)	
	``	Y Y		Required Required 1 to 5	EA prereq 2 EA prereq 3 EAc1.1	Minimum Energy Performance 10% Reduction in lighting power density from ASHRAE 90.1-2007 AND Fundamental Refrigerant Management Optimize Energy Performance: Lighting Power Reduce power density to 15% below Standard Reduce power density to 20% below Standard Reduce power density to 25% below Standard Reduce power density to 30% below Standard Reduce power density to 35% below Standard Optimize Energy Performance: Light Controls Option A - Daylight responsive controls within 15' of windows Option B - Daylight responsive controls for 50% of load Optimize Energy Performance: HVAC Option A - Equipment Efficiency and Zoning & Controls (RP) Option B - Reduce Design Energy Cost (RP)	
	``	Y Y		Required Required 1 to 5	EA prereq 2 EA prereq 3 EAc1.1	Minimum Energy Performance 10% Reduction in lighting power density from ASHRAE 90.1-2007 AND Fundamental Refrigerant Management Optimize Energy Performance: Lighting Power Reduce power density to 15% below Standard Reduce power density to 20% below Standard Reduce power density to 25% below Standard Reduce power density to 35% below Standard Reduce power density to 30% below Standard Optimize Energy Performance: Light Controls Option A - Daylight responsive controls within 15' of windows Option B - Daylight responsive controls for 50% of load Option C - Occupancy controls for 75% of load Optimize Energy Performance: HVAC Option A - Equipment Efficiency and Zoning & Controls (RP) Optimize Energy Performance: Equipment/Appliances	
	``	Y Y		Required Required 1 to 5 1 to 3	EA prereq 2 EA prereq 3 EAc1.1 EAc1.2	Minimum Energy Performance 10% Reduction in lighting power density from ASHRAE 90.1-2007 AND Fundamental Refrigerant Management Optimize Energy Performance: Lighting Power Reduce power density to 15% below Standard Reduce power density to 20% below Standard Reduce power density to 25% below Standard Reduce power density to 35% below Standard Reduce power density to 35% below Standard Optimize Energy Performance: Light Controls Option A - Daylight responsive controls within 15' of windows Option B - Daylight responsive controls for 50% of load Optimize Energy Performance: HVAC Option A - Equipment Efficiency and Zoning & Controls (RP) Optimize Energy Performance: Equipment/Appliances 70% of eligible equipment is ENERGY STAR	
	``	Y Y		Required Required 1 to 5 1 to 3	EA prereq 2 EA prereq 3 EAc1.1 EAc1.2	Minimum Energy Performance 10% Reduction in lighting power density from ASHRAE 90.1-2007 AND Fundamental Refrigerant Management Optimize Energy Performance: Lighting Power Reduce power density to 15% below Standard Reduce power density to 20% below Standard Reduce power density to 25% below Standard Reduce power density to 35% below Standard Reduce power density to 35% below Standard Optimize Energy Performance: Light Controls Option A - Daylight responsive controls within 15' of windows Option B - Daylight responsive controls for 50% of load Option C - Occupancy controls for 75% of load Optimize Energy Performance: HVAC Option A - Equipment Efficiency and Zoning & Controls (RP) Optimize Energy Performance: Equipment/Appliances 70% of eligible equipment is ENERGY STAR	
1	``	Y Y		Required Required 1 to 5 1 to 3	EA prereq 2 EA prereq 3 EAc1.1 EAc1.2	Minimum Energy Performance 10% Reduction in lighting power density from ASHRAE 90.1-2007 AND Fundamental Refrigerant Management Optimize Energy Performance: Lighting Power Reduce power density to 15% below Standard Reduce power density to 20% below Standard Reduce power density to 25% below Standard Reduce power density to 35% below Standard Reduce power density to 30% below Standard Optimize Energy Performance: Light Controls Option A - Daylight responsive controls within 15' of windows Option B - Daylight responsive controls for 50% of load Option C - Occupancy controls for 75% of load Option C - Decupancy controls for 75% of load Option A - Equipment Efficiency and Zoning & Controls (RP) Option B - Reduce Design Energy Cost (RP) Optimize Energy Performance: Equipment/Appliances 70% of eligible equipment is ENERGY STAR 84% of eligible equipment is ENERGY STAR	
1	``	Y Y		Required Required 1 to 5 1 to 3	EA prereq 2 EA prereq 3 EAc1.1 EAc1.2 EAc1.2	Minimum Energy Performance 10% Reduction in lighting power density from ASHRAE 90.1-2007 AND Fundamental Refrigerant Management Optimize Energy Performance: Lighting Power Reduce power density to 15% below Standard Reduce power density to 20% below Standard Reduce power density to 25% below Standard Reduce power density to 35% below Standard Reduce power density to 35% below Standard Optimize Energy Performance: Light Controls Option A - Daylight responsive controls within 15' of windows Option B - Daylight responsive controls for 50% of load Optimize Energy Performance: HVAC Option A - Equipment Efficiency and Zoning & Controls (RP) Option B - Reduce Design Energy Cost (RP) Optimize Energy Performance: Equipment/Appliances 70% of eligible equipment is ENERGY STAR 84% of eligible equipment is ENERGY STAR	
1	``	Y Y		Required Required 1 to 5 1 to 3	EA prereq 2 EA prereq 3 EAc1.1 EAc1.2 EAc1.2	Minimum Energy Performance 10% Reduction in lighting power density from ASHRAE 90.1-2007 AND Fundamental Refrigerant Management Optimize Energy Performance: Lighting Power Reduce power density to 15% below Standard Reduce power density to 20% below Standard Reduce power density to 25% below Standard Reduce power density to 35% below Standard Reduce power density to 35% below Standard Optimize Energy Performance: Light Controls Option A - Daylight responsive controls within 15' of windows Option B - Daylight responsive controls for 50% of load Option C - Occupancy controls for 75% of load Optimize Energy Performance: HVAC Option A - Equipment Efficiency and Zoning & Controls (RP) Option B - Reduce Design Energy Cost (RP) Optimize Energy Performance: Equipment/Appliances 70% of eligible equipment is ENERGY STAR 84% of eligible equipment is ENERGY STAR 84% of eligible equipment is ENERGY STAR Enhanced Commissioning Measurement & Verification	
1	``	Y Y		Required Required 1 to 5 1 to 3	EA prereq 2 EA prereq 3 EAc1.1 EAc1.2 EAc1.2	Minimum Energy Performance 10% Reduction in lighting power density from ASHRAE 90.1-2007 AND Fundamental Refrigerant Management Optimize Energy Performance: Lighting Power Reduce power density to 15% below Standard Reduce power density to 20% below Standard Reduce power density to 25% below Standard Reduce power density to 35% below Standard Reduce power density to 35% below Standard Optimize Energy Performance: Light Controls Option A - Daylight responsive controls within 15' of windows Option B - Daylight responsive controls for 50% of load Optimize Energy Performance: HVAC Option C - Occupancy controls for 75% of load Optimize Energy Performance: HVAC Option B - Reduce Design Energy Cost (RP) Option B - Reduce Design Energy Cost (RP) Optimize Energy Performance: Equipment/Appliances 70% of eligible equipment is ENERGY STAR 84% of eligible equipment is ENERGY STAR 84% of eligible equipment is ENERGY STAR Bolia equipment is ENERGY STAR Enhanced Commissioning Measurement & Verification Case 1 - Install Sub-Metering Equipment (2 pts)	
1	``	Y Y		Required Required 1 to 5 1 to 3 5 to 10	EA prereq 2 EA prereq 3 EAc1.1 EAc1.2 EAc1.3	Minimum Energy Performance 10% Reduction in lighting power density from ASHRAE 90.1-2007 AND Fundamental Refrigerant Management Optimize Energy Performance: Lighting Power Reduce power density to 15% below Standard Reduce power density to 20% below Standard Reduce power density to 25% below Standard Reduce power density to 35% below Standard Reduce power density to 35% below Standard Optimize Energy Performance: Light Controls Option A - Daylight responsive controls within 15' of windows Option B - Daylight responsive controls for 50% of load Option C - Occupancy controls for 75% of load Optimize Energy Performance: HVAC Option A - Equipment Efficiency and Zoning & Controls (RP) Option B - Reduce Design Energy Cost (RP) Optimize Energy Performance: Equipment/Appliances 70% of eligible equipment is ENERGY STAR 84% of eligible equipment is ENERGY STAR 84% of eligible equipment is ENERGY STAR Enhanced Commissioning Measurement & Verification	

5				5	EAc4	Green Power	
8	0	0	0	14 Points		MATERIALS & RESOURCES	
	L Y	,		Required	MR prereq 1	Storage & Collection of Recyclables	
1				1	MRc1.1	Tenant Space, Long Term Commitment	
1				1	MRc1.2	Building Reuse, Maintain 40% Interior Non-Structural Components	
_				1	MRc1.3	Building Reuse, Maintain 60% Interior Non-Structural Components	
1				2	MRc2.1	Construction Waste Management, Divert 50% from Landfill	
1					MRc2.2	Construction Waste Management, Divert 75% from Landfill	
1				2	MRc3.1 - 3.2	Materials Reuse, (5%, 10% Materials) (RP)	
				1	MRc3.3	Materials Reuse 30% Furniture and Furnishings	
1				1	MRc4.1	Recycled Content, 10% (post-consumer + 1/2 pre-consumer)	
				1	MRc4.2	Recycled Content, 20% (post-consumer + 1/2 pre-consumer)	
1				1	MRc5.1	Regional Materials, 20% Manufactured Regionally (RP)	
				1	MRc5.2	Regional Materials, 10% Extracted and Manufactured Regionally	
				1	MRc6	Rapidly Renewable Materials	
1				1	MRc7	Certified Wood	
7	0	0	0	17 Points		INDOOR ENVIRONMENTAL QUALITY	
	Y	,		Required	EQ prereq 1	Minimum IAQ Performance	
	Y	,		Required	EQ prereq 2	Environmental Tobacco Smoke Control	
				1	EQc1	Outside Air Delivery Monitoring	
				1	EQc2	Increased Ventilation	
1				1	EQc3.1	Construction IAQ Management Plan, During Construction	
				1	EQc3.2	Construction IAQ Management Plan, Before Occupancy	
1				1	EQc4.1	Low-Emitting Materials, Adhesives and Sealants	
1				1	EQc4.2	Low-Emitting Materials, Paints and Coatings	
1				1	EQc4.3	Low-Emitting Materials, Flooring Systems	
1				1	EQc4.4	Low-Emitting Materials, Composite Wood & Laminate Adhesives	
1				1	EQc4.5	Low-Emitting Materials, Systems Furniture and Seating	
				1	EQc5	Indoor Chemical and Pollutant Source Control	
				1	EQc6.1	Controllability of Systems, Lighting	
				1	EQc6.2	Controllability of Systems, Thermal Comfort	
				1	EQc7.1	Thermal Comfort, Design	
				1	EQc7.1	Thermal Comfort, Verification	
1				1		Daylight and Views, Daylight 75% of Spaces	
-				1	EQc8.2	Daylight and Views, Daylight 13% of Spaces Daylight and Views, Daylight 90% of Spaces	
				1	EQc8.3	Daylight and Views, Views for 90% of Seated Spaces	
6	0	0	0	6 Points	_000.3	INNOVATION AND DESIGN PROCESS (max 3 Exemplary Performance points)	
1				1	IDc1.1	IDc1.1: Exemplary Performance: Green Power	
1				1		IDc1.2: Exemplary Performance: Community Connectivity	
1				1	IDc1.3	IDc1.3: Exemplary Performance: MRc3.2 Furniture Reuse	
1				1	IDc1.4	IDc1.4: PC13 Bicycle Network, Storage, and Changing Rooms	
1				1		IDc1.5: PC12: Reduced Automobile Dependence	1
1				1		IDc2 LEED AP	
3	0	0	0	4 Points		REGIONAL PRIORITY CREDITS	
1				1	RP	Regional Priority Credit: See SSc3.2(RP) above	
				1	RP	Regional Priority Credit: See EAc1.1(RP) above	
1				1	RP	Regional Priority Credit: See MRc3.1-3.2(RP) above	
1				1	RP	Regional Priority Credit: See MRc5.1(RP) above	
70	0	0	0	70		TOTAL (pre-certification estimates)	
	ied 40			Silver 50 to		Gold 60 to 79 points Platinum 80 to 110 points	